

Schedule 40 Pipe					Max. Work Press.		
Size	O.D.	Ave. I.D.	Min. Wall Thickness	Approx. Wt. Per 100'	Plain Ends	Gray	White
1/4"	0.54	0.354	0.088	7.88	780	26300	
3/8"	0.675	0.483	0.091	10.53	620	26301	
1/2"	0.84	0.608	0.109	15.63	600	26302	26502
3/4"	1.05	0.804	0.113	20.78	480	26303	26503
1"	1.315	1.033	0.133	30.85	450	26304	26504
1-1/4"	1.66	1.364	0.14	41.76	370	26305	26505
1-1/2"	1.9	1.592	0.145	49.94	330	26306	26506
2"	2.375	2.049	0.154	67.92	280	26307	26507
2-1/2"	2.875	2.445	0.203	105.46	300	26308	26508
3"	3.5	3.042	0.216	137.91	260	26309	26509
4"	4.5	3.998	0.237	194.58	220	26310	26510
6"	6.625	6.031	0.28	338.88	180	26311	26511

Schedule 80 Pipe					Max. Work Press. Press. Thrd.		
Size	O.D.	Ave. I.D.	Min. Wall Thickness	Approx. Wt. Per Foot	Plain Ends	Ends	Gray
1/4"	0.54	0.282	0.119	0.105	1130	550	26320
3/8"	0.675	0.403	0.126	0.146	920	450	26321
1/2"	0.84	0.546	0.147	0.213	850	420	26322
3/4"	1.05	0.722	0.154	0.289	690	340	26323
1"	1.315	0.936	0.179	0.424	630	320	26324
1-1/4"	1.66	1.255	0.191	0.586	520	260	26325
1-1/2"	1.9	1.476	0.2	0.711	470	240	26326
2"	2.375	1.913	0.218	0.984	400	210	26327
2-1/2"	2.875	2.29	0.276	1.5	420	200	26328
3"	3.5	2.864	0.3	2.01	370	190	26329
4"	4.5	3.786	0.337	2.938	320	160	26330
6"	6.625	5.709	0.432	5.61	280	140	26331